



NOTES:

- METER SHOWN IS THE NEPTUNE PROTECTUS COMBINATION METER. THIS WILL BE REPLACED WITH A SENSUS OMNI T2 IF FIRE SERVICE IS NOT REQUIRED.
- SIZES SHOWN ARE THE MINIMUM INSIDE DIMENSIONS. PIT TO BE SIZED AS REQUIRED TO ACCOMMODATE METER.
- SIZE OF PIPING SAME AS METER SIZE.
- ONLY BACKFLOW DEVICE APPROVED FOR PIT INSTALLATION IS DOUBLE CHECK. RPZ BACKFLOW ASSEMBLIES CANNOT BE INSTALLED IN PIT.

COMBINATION METER SIZES	MINIMUM VAULT SIZE W x L x H
3"	6.5'x11'x6'
4"	7.5'x13'x6.5'
6"	8.5'x15.5'x6.5'
8"	9'x17'x6.5'
10"	9.5'x19.5'x7'

HORSHAM WATER & SEWER AUTHORITY

DETAIL W5-A

WATER METER PIT FOR COMBINATION METERS > 2"

DATE:

FEBRUARY 18, 2016

SCALE:

NOT TO SCALE