

Source	Sample Collection Date	PFOS Result (ppt)	PFOA Result (ppt)	Combined PFOS PFOA total concentration (ppt)	Combined PFOS PFOA Health Advisory issued 5/19/16 (ppt)	Notes
Aqua Interconnect	7/11/2014	ND	ND	ND		Higher detection levels
Aqua Interconnect	9/24/2014	ND	ND	ND		Higher detection levels
Aqua Interconnect	12/12/2014	ND	ND	ND		Higher detection levels
Aqua Interconnect	3/19/2015	ND	ND	ND		Higher detection levels
Aqua Interconnect	4/13/2016	7.5	4.4	11.9		
Aqua Interconnect	4/25/2016	9.0	4.8	13.8		
Aqua Interconnect	5/3/2016	7.8	4.6	12.4		
Aqua Interconnect	7/20/2016	6.8	6.5	13.3	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	8/16/2016	12.0	6.4	18.4	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	9/14/2016	11.0	6.9	17.9	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	11/3/2016	5.6	7.0	12.6	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	2/15/2017	6.3	3.9	10.2	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	5/4/2017	20.0	11.0	31.0	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	6/15/2017	11.0	6.8	17.8	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	7/20/2017	14.0	8.9	22.9	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	8/17/2017	13.0	12.0	25.0	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	10/12/2017	4.8	7.3	12.1	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	11/16/2017	6.2	9.2	15.4	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	12/18/2017	9.9	9.2	19.1	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system

Aqua IC

Aqua Interconnect	1/18/2018	8.6	9.4	18.0	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	2/15/2018	6.6	7.3	13.9	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	3/15/2018	8.6	5.7	14.3	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	4/19/2018	12.0	7.7	19.7	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	5/10/2018	7.6	6.6	14.2	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	6/14/2018	13.0	10.0	23.0	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	7/19/2018	9.7	6.6	16.3	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	8/9/2018	7.8	7.6	15.4	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	8/16/2018	9.2	8.1	17.3	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	8/23/2018	8.9	7.8	16.7	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	8/29/2018	5.6	5.8	11.4	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	9/6/2018	6.6	7.1	13.7	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system

Aqua IC

Aqua Interconnect	9/13/2018	4.1	4.4	8.5	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	9/20/2018	6.0	6.3	12.3	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	10/11/2018	5.1	5.2	10.3	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	10/18/2018	4.8	8.0	12.8	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	11/1/2018	6.9	6.7	13.6	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	11/15/2018	5.3	7.5	12.8	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	12/6/2018	4.8	5.1	9.9	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	12/20/2018	8.5	6.9	15.4	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	1/3/2019	4.0	4.8	8.8	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	2/4/2019	5.4	5.8	11.2	70.0	Sample results are finished water from the Aqua PA main system entering the Horsham system

