

Source	Sample Collection Date	PFOS Result (ppt)	PFOA Result (ppt)	Combined PFOS PFOA total concentration (ppt)	PFNA Result (ppt)	PFHxS Result (ppt)	PFBS Result (ppt)	PFHpA Result (ppt)	PFHxA Result (ppt)	Notes
Aqua Interconnect	7/11/2014	ND	ND	ND						UCMR Higher detection levels
Aqua Interconnect	9/24/2014	ND	ND	ND						UCMR Higher detection levels
Aqua Interconnect	12/12/2014	ND	ND	ND						UCMR Higher detection levels
Aqua Interconnect	3/19/2015	ND	ND	ND						UCMR Higher detection levels
Aqua Interconnect	4/13/2016	7.5	4.4	11.9						
Aqua Interconnect	4/25/2016	9.0	4.8	13.8						
Aqua Interconnect	5/3/2016	7.8	4.6	12.4						
Aqua Interconnect	7/20/2016	6.8	6.5	13.3						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	8/16/2016	12.0	6.4	18.4						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	9/14/2016	11.0	6.9	17.9						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	11/3/2016	5.6	7.0	12.6						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	2/15/2017	6.3	3.9	10.2						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	5/4/2017	20.0	11.0	31.0						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	6/15/2017	11.0	6.8	17.8						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	7/20/2017	14.0	8.9	22.9						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	8/17/2017	13.0	12.0	25.0						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	10/12/2017	4.8	7.3	12.1						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	11/16/2017	6.2	9.2	15.4						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	12/18/2017	9.9	9.2	19.1						Sample results are finished water from the Aqua PA main system entering the Horsham system

Aqua IC

Aqua Interconnect	1/18/2018	8.6	9.4	18.0						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	2/15/2018	6.6	7.3	13.9						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	3/15/2018	8.6	5.7	14.3						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	4/19/2018	12.0	7.7	19.7						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	5/10/2018	7.6	6.6	14.2						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	6/14/2018	13.0	10.0	23.0						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	7/19/2018	9.7	6.6	16.3						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	8/9/2018	7.8	7.6	15.4						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	8/16/2018	9.2	8.1	17.3						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	8/23/2018	8.9	7.8	16.7						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	8/29/2018	5.6	5.8	11.4						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	9/6/2018	6.6	7.1	13.7						Sample results are finished water from the Aqua PA main system entering the Horsham system

Aqua IC

Aqua Interconnect	9/13/2018	4.1	4.4	8.5						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	9/20/2018	6.0	6.3	12.3						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	10/11/2018	5.1	5.2	10.3						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	10/18/2018	4.8	8.0	12.8						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	11/1/2018	6.9	6.7	13.6						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	11/15/2018	5.3	7.5	12.8						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	12/6/2018	4.8	5.1	9.9						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	12/20/2018	8.5	6.9	15.4						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	1/3/2019	4.0	4.8	8.8						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	2/4/2019	5.4	5.8	11.2						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	3/4/2019	5.2	5.8	11.0						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	3/18/2019	5.1	5.7	10.8						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	4/15/2019	5.2	5.6	10.8						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	5/8/2019	5.3	5.5	10.8						Sample results are finished water from the Aqua PA main system entering the Horsham system

Aqua IC

Aqua Interconnect	6/3/2019	5.0	3.7	8.7						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	6/17/2019	4.8	5.1	9.9						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	7/1/2019	5.4	5.6	11.0						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	7/15/2019	5.5	5.0	10.5						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	8/19/2019	10.0	18.0	28.0						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	9/4/2019	5.0	4.1	9.1						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	9/16/2019	ND	ND	ND						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	10/7/2019	4.5	4.5	9.0						Sample results are finished water from the Aqua PA main system entering the Horsham system
Aqua Interconnect	10/21/2019	3.1	2.8	5.9						Sample results are finished water from the Aqua PA main system that would supply the Horsham system. Interconnect was suspended 10/8/19
Aqua Interconnect	11/5/2019	ND	3.1	3.1						Sample results are finished water from the Aqua PA main system that would supply the Horsham system. Interconnect was suspended 10/8/19
Aqua Interconnect	11/18/2019	4.7	4.4	9.1						Sample results are finished water from the Aqua PA main system that would supply the Horsham system. Interconnect was suspended 10/8/19
Aqua Interconnect	12/4/2019	5.3	5.2	10.5						Sample results are finished water from the Aqua PA main system that would supply the Horsham system. Interconnect was suspended 10/8/19
Aqua Interconnect	12/16/2019	4.4	4.2	8.6						Sample results are finished water from the Aqua PA main system that would supply the Horsham system. Interconnect was suspended 10/8/19
Aqua Interconnect	1/6/2020	3.2	3.4	6.6						Sample results are finished water from the Aqua PA main system that would supply the Horsham system. Interconnect was suspended 10/8/19
Aqua Interconnect	1/20/2020	5.0	4.7	9.7						Sample results are finished water from the Aqua PA main system that would supply the Horsham system. Interconnect was suspended 10/8/19
Aqua Interconnect	1/30/2020	4.1	4.1	8.2	ND	2.6	2.5	ND	3.4	Sample results are finished water from the Aqua PA main system that would supply the Horsham system. Interconnect was suspended 10/8/19
Aqua Interconnect	2/3/2020	4.7	4.0	8.7						Sample results are finished water from the Aqua PA main system that would supply the Horsham system. Interconnect was suspended 10/8/19
Aqua Interconnect	2/20/2020	3.4	4.5	7.9						Sample results are finished water from the Aqua PA main system that would supply the Horsham system. Interconnect was suspended 10/8/19

Aqua IC

Aqua Interconnect	3/2/2020	ND	ND	ND						Sample results are finished water from the Aqua PA main system that would supply the Horsham system. Interconnect was suspended 10/8/19
Aqua Interconnect	3/16/2020	6.2	5.2	11.4						Sample results are finished water from the Aqua PA main system that would supply the Horsham system. Interconnect was suspended 10/8/19
Aqua Interconnect	4/6/2020	ND	ND	ND						Sample results are finished water from the Aqua PA main system that would supply the Horsham system. Interconnect was suspended 10/8/19
Aqua Interconnect	5/4/2020	ND	2.5	2.5						Sample results are finished water from the Aqua PA main system that would supply the Horsham system. Interconnect was suspended 10/8/19
Aqua Interconnect	5/18/2020	ND	ND	ND						Sample results are finished water from the Aqua PA main system that would supply the Horsham system. Interconnect was suspended 10/8/19
Aqua Interconnect	6/2/2020	2.3	ND	2.3						Sample results are finished water from the Aqua PA main system that would supply the Horsham system. Interconnect was suspended 10/8/19
Aqua Interconnect	6/15/2020	ND	ND	ND						Sample results are finished water from the Aqua PA main system that would supply the Horsham system. Interconnect was suspended 10/8/19
Aqua Interconnect	8/26/2020	ND	5.6	5.6	ND	3.0	3.1	2.6	4.7	Sample results are influent to HWSA GAC treatment facility (started 8/17/2020)
Aqua Interconnect	9/9/2020	ND	4.6	4.6	ND	3.0	3.0	ND	5.3	Sample results are influent to HWSA GAC treatment facility
Aqua Interconnect	9/8/2020	3.8	5.7	9.5						Sample results are finished water from the Aqua PA main system that supply the Horsham system.
Aqua Interconnect	10/14/2020	3.2	4.7	7.9	ND	4.6	3.3	ND	5.2	Sample results are influent to HWSA GAC treatment facility
Aqua Interconnect	10/19/2020	4	5.5	9.5						Sample results are finished water from the Aqua PA main system that supply the Horsham system.
Aqua Interconnect	11/10/2020	4.5	5.8	10.3	ND	4.2	3.1	4.6	4.2	Sample results are influent to HWSA GAC treatment facility
Aqua Interconnect	11/17/2020	5.1	5.6	10.7						Sample results are finished water from the Aqua PA main system that supply the Horsham system.
Aqua Interconnect	12/9/2020	2.9	5.3	8.2	ND	4.0	3.0	ND	3.2	Sample results are influent to HWSA GAC treatment facility
Aqua Interconnect	12/21/2020	ND	3.7	3.7						Sample results are finished water from the Aqua PA main system that supply the Horsham system.
Aqua Interconnect	1/13/2021	3.7	3.9	7.6	ND	3.4	2.5	3.1	3.6	Sample results are influent to HWSA GAC treatment facility
Aqua Interconnect	1/18/2021	ND	ND	ND						Sample results are finished water from the Aqua PA main system that supply the Horsham system.

Aqua IC

Aqua Interconnect	2/10/2021	3.1	4.3	7.4	ND	2.5	3.3	3.3	5.2	Sample results are influent to HWSA GAC treatment facility
Aqua Interconnect	2/16/2021	ND	ND	ND						Sample results are finished water from the Aqua PA main system that supply the Horsham system (collected by Aqua PA).
Aqua Interconnect	3/10/2021	3.9	5	8.9	ND	4.2	3.8	2.6	4.9	Sample results are influent to HWSA GAC treatment facility
Aqua Interconnect	3/16/2021	4.3	4.6	8.9						Sample results are finished water from the Aqua PA main system that supply the Horsham system (collected by Aqua PA).
Aqua Interconnect	4/14/2021	3.4	4.3	7.7	ND	2.5	ND	ND	4.3	Sample results are influent to HWSA GAC treatment facility
Aqua Interconnect	4/19/2021	ND	3.3	3.3						Sample results are finished water from the Aqua PA main system that supply the Horsham system (collected by Aqua PA).
Aqua Interconnect	5/12/2021	4.1	3.9	8.0	ND	3.4	4.4	ND	5.0	Sample results are influent to HWSA GAC treatment facility
Aqua Interconnect	5/17/2021	ND	ND	ND						Sample results are finished water from the Aqua PA main system that supply the Horsham system (collected by Aqua PA).
Aqua Interconnect	6/9/2021	3.3	4.9	8.2	ND	2.8	4.1	ND	4.2	Sample results are influent to HWSA GAC treatment facility
Aqua Interconnect	6/21/2021	5.3	4.4	9.7						Sample results are finished water from the Aqua PA main system that supply the Horsham system (collected by Aqua PA).
Aqua Interconnect	7/14/2021	4.8	4.7	9.5	0.68J	3.4	3.5	2.0	4.7	Sample results are influent to HWSA GAC treatment facility. Results are Method 537.1 analyzed by Eurofins
Aqua Interconnect	7/19/2021	4.9	3.6	8.5						Sample results are finished water from the Aqua PA main system that supply the Horsham system (collected by Aqua PA).
Aqua Interconnect	8/11/2021	4.2	5.6	9.8	ND	4.8	5.7	ND	6.0	Sample results are influent to HWSA GAC treatment facility
Aqua Interconnect	8/16/2021	ND	ND	ND						Sample results are finished water from the Aqua PA main system that supply the Horsham system (collected by Aqua PA).
Aqua Interconnect	9/8/2021	8.4	5.8	14.2	ND	3.1	5.3	3.0	4.9	Sample results are influent to HWSA GAC treatment facility
Aqua Interconnect	10/13/2021	5.9	5.8	11.7	ND	2.6	4.0	ND	4.0	Sample results are influent to HWSA GAC treatment facility
Aqua Interconnect	10/18/2021	6.7	6.2	12.9						Sample results are finished water from the Aqua PA main system that supply the Horsham system (collected by Aqua PA).
Aqua Interconnect	11/10/2021	3.8	3.1	6.9	ND	ND	3.8	ND	4.2	Sample results are influent to HWSA GAC treatment facility (collected by HWSA)

Aqua Interconnect	11/15/2021	ND	2.6	2.6						Sample results are finished water from the Aqua PA main system that supply the Horsham system (collected by Aqua PA).
Aqua Interconnect	12/8/2021	5.3	6.3	11.6	ND	3.9	3.4	ND	2.8	Sample results are influent to HWSA GAC treatment facility (collected by HWSA)
Aqua Interconnect	12/20/2021	ND	2.6	2.6						Sample results are finished water from the Aqua PA main system that supply the Horsham system (collected by Aqua PA).

