

Well No.	Sample Collection Date	Perfluorohexanesulfonic acid PFHxS C ₆ HF ₁₃ O ₃ S	Perfluorononanoic acid PFNA C ₉ HF ₁₇ O ₂	Perfluorooctanesulfonic acid PFOS C ₈ HF ₁₇ O ₃ S	Perfluorooctanoic acid PFOA C ₈ HF ₁₅ O ₂	Combined PFOS PFOA total concentration, ppt	
	Date	PFHxS	PFNA	PFOS	PFOA	Combined PFOS/PFOA	
17	1/26/2017	ND	ND	ND	ND	ND	GAC started 1/20/2017
17	2/3/2017	42	ND	78	22	100	
17	2/8/2017						
17	2/23/2017						
17	3/4/2017	ND	ND	ND	ND	ND	
17	3/16/2017	ND	ND	ND	ND	ND	
17	3/24/2017			ND	ND	ND	
17	4/5/2017	47.0	ND	71.0	28.0	99.0	
17	4/18/2017			3.1	ND	3.1	
17	5/2/2017			ND	ND	ND	
17	6/2/2017			103.0	31.0	134.0	
17	6/3/2017	36.0	ND	65.0	19.0	84.0	
17	6/6/2017			159.0	28.0	188.0	
17	6/14/2017	36.0	ND	64.0	19.0	83.0	
17	6/23/2017			ND	ND	ND	
17	6/28/2017	ND	ND	ND	ND	ND	
17	7/2/2017	ND	ND	ND	ND	ND	
17	7/12/2017	ND	ND	ND	ND	ND	
17	7/21/2017						GAC Change Out 7/19/2017
17	7/26/2017	ND	ND	ND	ND	ND	
17	8/8/2017	ND	ND	ND	ND	ND	
17	8/23/2017	ND	ND	ND	ND	ND	
17	9/6/2017	ND	ND	ND	ND	ND	
17	9/20/2017	ND	ND	ND	ND	ND	
17	10/4/2017	ND	ND	ND	ND	ND	
17	10/18/2017	ND	ND	ND	ND	ND	
17	10/30/2017	ND	ND	ND	ND	ND	
17	11/15/2017	ND	ND	ND	ND	ND	

17	11/28/2017	ND	ND	ND	ND	ND
17	12/12/2017	ND	ND	ND	ND	ND
17	12/27/2017	ND	ND	ND	ND	ND
17	1/10/2018	ND	ND	ND	ND	ND
17	1/23/2018	ND	ND	ND	ND	ND
17	2/7/2018	ND	ND	ND	ND	ND
17	2/22/2018	ND	ND	ND	ND	ND
17	3/6/2018	ND	ND	ND	ND	ND
17	3/23/2018	ND	ND	ND	ND	ND
17	4/3/2018	ND	ND	ND	ND	ND
17	4/10/2018	ND	ND	ND	ND	ND
17	4/18/2018	ND	ND	ND	ND	ND
17	5/1/2018	ND	ND	ND	ND	ND
17	5/15/2018	ND	ND	ND	ND	ND
17	5/30/2018	ND	ND	ND	ND	ND
17	6/11/2018	ND	ND	ND	ND	ND
GAC Change Out 7/9/2018						
17	7/6/2018	ND	ND	ND	ND	ND
17	8/8/2018	ND	ND	ND	ND	ND
17	8/22/2018	ND	ND	ND	ND	ND
17	9/5/2018	ND	ND	ND	ND	ND
17	9/19/2018	ND	ND	ND	ND	ND
17	10/3/2018	ND	ND	ND	ND	ND
17	10/17/2018	ND	ND	ND	ND	ND
17	11/1/2018	ND	ND	ND	ND	ND
17	11/14/2018	ND	ND	ND	ND	ND
17	11/28/2018	ND	ND	ND	ND	ND
17	12/11/2018	ND	ND	ND	ND	ND
17	12/27/2018	ND	ND	ND	ND	ND
17	1/9/2019	ND	ND	ND	ND	ND

Well 17 Treated Water - Currently Active

