

Well No.	Sample Collection Date	Perfluorohexanesulfonic acid PFHxS C ₆ HF ₁₃ O ₃ S	Perfluorononanoic acid PFNA C ₉ HF ₁₇ O ₂	Perfluorooctanesulfonic acid PFOS C ₈ HF ₁₇ O ₃ S	Perfluorooctanoic acid PFOA C ₈ HF ₁₅ O ₂	Combined PFOS PFOA total concentration, ppt	
	Date	PFHxS	PFNA	PFOS	PFOA	Combined PFOS/PFOA	
26	3/24/2017			ND	ND	ND	GAC started 3/20/2017
26	3/24/2017	ND	ND	ND	ND	ND	
26	4/5/2017	ND	ND	ND	ND	ND	
26	4/18/2017			ND	ND	ND	
26	5/3/2017			ND	ND	ND	
26	6/1/2017	ND	ND	ND	ND	ND	
26	6/6/2017			ND	ND	ND	
26	6/27/2017			ND	ND	ND	
26	7/11/2017	ND	ND	ND	ND	ND	
26	7/26/2017	ND	ND	ND	ND	ND	GAC Change out 7/12/2017
26	8/9/2017	ND	ND	ND	ND	ND	
26	8/23/2017	ND	ND	ND	ND	ND	
26	9/6/2017	ND	ND	ND	ND	ND	
26	9/20/2017	ND	ND	ND	ND	ND	
26	10/4/2017	ND	ND	ND	ND	ND	
26	10/18/2017	ND	ND	ND	ND	ND	
26	10/30/2017	ND	ND	ND	ND	ND	
26	11/15/2017	ND	ND	ND	ND	ND	
26	11/28/2017	ND	ND	ND	ND	ND	
26	12/12/2017	ND	ND	ND	ND	ND	
26	12/27/2017	ND	ND	ND	ND	ND	
26	1/10/2018	ND	ND	ND	ND	ND	
26	1/23/2018	ND	ND	ND	ND	ND	
26	2/7/2018	ND	ND	ND	ND	ND	
26	2/22/2018	ND	ND	ND	ND	ND	
26	3/23/2018	ND	ND	ND	ND	ND	

26	4/3/2018	ND	ND	ND	ND	ND
26	4/4/2018	ND	ND	ND	ND	ND
26	4/18/2018	ND	ND	ND	ND	ND
26	5/1/2018	ND	ND	ND	ND	ND
26	5/15/2018	ND	ND	ND	ND	ND
26	5/30/2018	ND	ND	ND	ND	ND

GAC
Change out
6/12/2018

26	6/26/2018	ND	ND	ND	ND	ND
26	7/11/2018	ND	ND	ND	ND	ND
26	8/9/2018	ND	ND	ND	ND	ND
26	8/22/2018	ND	ND	ND	ND	ND
26	9/5/2018	ND	ND	ND	ND	ND
26	9/19/2018	ND	ND	ND	ND	ND
26	10/3/2018	ND	ND	ND	ND	ND
26	10/17/2018	ND	ND	ND	ND	ND
26	11/1/2018	ND	ND	ND	ND	ND
26	11/14/2018	ND	ND	ND	ND	ND
26	12/11/2018	ND	ND	ND	ND	ND
26	12/27/2018	ND	ND	ND	ND	ND
26	1/9/2019	ND	ND	ND	ND	ND
26	1/24/2019	ND	ND	ND	ND	ND
26	2/5/2019	ND	ND	ND	ND	ND
26	2/20/2019	ND	ND	ND	ND	ND
26	3/6/2019	ND	ND	ND	ND	ND
26	3/20/2019	ND	ND	ND	ND	ND
26	4/3/2019	ND	ND	ND	ND	ND
26	4/17/2019	ND	ND	ND	ND	ND
26	5/1/2019	ND	ND	ND	ND	ND
26	5/15/2019	ND	ND	ND	ND	ND
26	5/29/2019	ND	ND	ND	ND	ND

GAC
Changeout
6/13 -
7/9/2019

26	6/12/2019	ND	ND	ND	ND	ND
26	7/10/2019	ND	ND	ND	ND	ND

Well #26 Treated Water - Currently Active

