

Well No.	Sample Collection Date	Perfluorooctanesulfonic acid PFOS C <sub>8</sub> HF <sub>17</sub> O <sub>3</sub> S	Perfluorooctanoic acid PFOA C <sub>8</sub> HF <sub>15</sub> O <sub>2</sub>	Combined PFOS PFOA	Perfluorohexanesulfonic acid PFHxS C <sub>6</sub> HF <sub>13</sub> O <sub>3</sub> S	Perfluorononanoic acid PFNA C <sub>9</sub> HF <sub>17</sub> O <sub>2</sub>	Perfluorobutanesulfonic acid PFBS C <sub>4</sub> HF <sub>9</sub> O <sub>3</sub> S	Perfluoroheptanoic acid PFHpA C <sub>7</sub> HF <sub>13</sub> O <sub>2</sub>	Perfluorohexanoic acid PFHxA <sup>†</sup> C <sub>6</sub> HF <sub>11</sub> O <sub>2</sub>	
	Date	PFOS (ppt)	PFOA (ppt)	Combined PFOS/PFOA (ppt)	PFHxs (ppt)	PFNA (ppt)	PFBS (ppt)	PFHpA (ppt)	PFHxA (ppt)	Comments
2	6/25/2014	ND	ND	ND	ND	ND	ND	ND		UCMR Higher detection levels
2	12/12/2014	ND	ND	ND	ND	ND	ND	ND		UCMR Higher detection levels
2	12/15/2015	16.0	17.0	33.0	12.0	ND	4.9	5.2	7.7	
2	5/10/2016	18.0	10.0	28.0	7.7	ND	3.0	3.2	4.6	
2	7/27/2016	23.0	14.0	37.0	10.0	ND	4.1	4.3	6.5	
2	8/10/2016	27.0	16.0	43.0	12.0	ND	4.2	5.0	7.4	
2	9/22/2016	39.0	19.0	58.0	11.0	3.3	3.9	5.4	8.6	
2	10/12/2016	21.0	16.0	37.0	11.0	ND	4.8	4.7	7.1	
2	10/25/2016	20.0	22.0	42.0	10.0	3.1	4.0	5.8	7.9	
2	11/9/2016	21.0	14.0	35.0	11.0	ND	4.7	4.5	6.5	
2	12/1/2016	14.0	9.6	23.6	8.8	ND	3.1	2.5	4.0	
2	12/14/2016	14.0	9.6	23.6	8.8	ND	3.1	4.0	4.0	
2	1/11/178	9.6	9.1	18.7	8.4	ND	4.5	2.6	3.8	
2	2/1/2017	18.3	10.2	28.5						
2	2/23/2017	11.1	8.7	19.8	11.7	ND	4.2	2.6	3.8	
2	3/9/2017	16.0	8.7	24.7	8.8	ND	3.2	2.7	3.7	
2	3/24/2017	12.1	10.2	22.3						
2	4/4/2017	19.4	9.7	29.1						
2	5/3/2017	27.0	12.0	39.0						
2	5/31/2017	29.0	12.0	41.0						
2	7/7/2017	29.0	16.0	45.0	16.0	ND	5.6	4.7		
2	7/21/2017	30.0	14.0	44.0	16.0	ND	5.5	5.8		
2	8/1/2017	25.0	11.0	36.0	14.0	ND	5.6	3.8		
2	8/16/2017	29.0	11.0	40.0	15.0	ND	5.6	6.1		
2	9/7/2017	29.0	11.0	40.0	14.0	ND	5.0	5.0		
2	9/19/2017	24.0	10.0	34.0	13.0	ND	3.4	4.2		
2	10/4/2017	24.0	9.7	33.7	15.0	ND	5.4	4.2		
2	10/17/2017	28.0	11.0	39.0	17.0	ND	6.0	2.9		
2	11/9/2017	22.0	10.0	32.0	9.1	ND	3.3	2.8		
2	11/22/2017	18.0	8.7	26.7	9.1	ND	3.3	3.2		
2	12/5/2017	15.0	11.0	26.0	12.0	ND	4.2	4.2		
2	12/19/2017	20.0	9.9	29.9	13.0	ND	3.8	4.3		
2	1/5/2018	22.0	10.0	32.0	9.4	ND	4.7	3.7		
2	1/16/2018	20.0	11.0	31.0	8.5	ND	3.9	4.3		
2	4/4/2019	21.0	10.0	31.0	9.4	ND	4.5	4.5		Values in red mean lab is not certified in PA for compound
2	9/4/2019	19.0	11.0	30.0	9.8	ND	5.3	3.1	4.3	Well 2 placed back in service on 8/23/2019
2	10/2/2019	26.0	17.0	43.0	15.0	ND	6.5	5.0	7.0	
2	10/16/2019	21.0	18.0	39.0	15.0	ND	6.7	5.2	7.3	
2	10/30/2019	21.0	16.0	37.0	11.0	ND	4.5	4.9	6.3	
2	11/12/2019	29.0	19.0	48.0	15.0	2.5	6.6	5.5	7.3	
2	11/26/2019	19.0	17.0	36.0	15.0	ND	6.5	5.6	8.5	
2	11/27/2019	24.0	16.0	40.0	12.0	2.0	5.2	4.8	7.3	Eurofins Method 537
2	12/11/2019	26.0	17.0	43.0	13.0	2.5	5.7	5.4	7.0	
2	12/26/2019	22.0	17.0	39.0	10.0	2.7	4.8	6.5	8.0	
2	1/8/2020	24.0	15.0	39.0	11.0	ND	5.0	5.1	7.2	Eurofins Method 537.1
2	1/8/2020	21.0	16.0	37.0	12.0	ND	5.4	6.3	8.2	
2	1/22/2020	21.0	15.0	36.0	9.8	ND	5.2	5.8	9.0	

2	2/4/2020	29.0	19.0	48.0	13.0	ND	6.7	5.6	8.7	
2	2/17/2020	21.0	15.0	36.0	11.0	ND	4.6	4.9	7.3	
2	3/4/2020	24.0	17.0	41.0	12.0	2.9	5.4	5.0	7.1	
2	3/18/2020	23.0	17.0	40.0	8.7	2.5	4.4	4.0	5.9	
2	3/31/2020	25.0	15.0	40.0	11.0	ND	5.4	4.6	6.7	
2	4/14/2020	26.0	15.0	41.0	11.0	ND	5.2	3.9	6.3	
2	4/29/2020	21.0	14.0	35.0	10.0	ND	5.6	3.6	7.2	
2	5/13/2020	26.0	13.0	39.0	11.0	ND	5.0	4.4	6.9	Sampling reduced to monthly per PADEP
2	6/3/2020	24.0	9.8	33.8	12.0	ND	4.9	3.9	5.5	
2	7/8/2020	23.0	17.0	40.0	11.0	ND	5.8	4.5	7.0	
2	8/12/2020	21.0	19.0	40.0	11.0	2.5	5.2	6.4	8.0	
2	9/9/2020	23.0	17.0	40.0	12.0	2.7	4.8	5.4	8.9	
2	10/14/2020	22.0	16.0	38.0	13.0	ND	5.1	5.0	7.8	
2	11/10/2020	32.0	24.0	56.0	15.0	4.0	5.9	8.5	10.0	

