

Well No.	Sample Collection Date	Perfluorohexanesulfonic acid PFHxS C ₆ HF ₁₃ O ₃ S	Perfluorononanoic acid PFNA C ₉ HF ₁₇ O ₂	Perfluorooctanesulfonic acid PFOS C ₈ HF ₁₇ O ₃ S	Perfluorooctanoic acid PFOA C ₈ HF ₁₅ O ₂	Combined PFOS PFOA total concentration, ppt	
	Date	PFHxS	PFNA	PFOS	PFOA	Combined PFOS/PFOA	
40	4/18/2017			ND	ND	ND	GAC started 4/20/2017
40	5/2/2017			ND	ND	ND	
40	6/1/2017	25.0	ND	38.0	3.2	41.2	
40	6/1/2017			56.0	5.1	61.1	
40	6/6/2017			131.0	5.3	136.3	
40	6/23/2017			ND	ND	ND	
40	6/27/2017	ND	ND	ND	ND	ND	
40	7/11/2017	ND	ND	ND	ND	ND	GAC change out 7/6/2017
40	7/26/2017	ND	ND	ND	ND	ND	
40	8/9/2017	ND	ND	ND	ND	ND	
40	8/23/2017	ND	ND	ND	ND	ND	
40	9/6/2017	ND	ND	ND	ND	ND	
40	9/20/2017	ND	ND	2.6	ND	2.6	
40	10/4/2017	ND	ND	ND	ND	ND	
40	10/18/2017	ND	ND	ND	ND	ND	
40	10/30/2017	ND	ND	ND	ND	ND	
40	11/15/2017	ND	ND	ND	ND	ND	
40	11/28/2017	ND	ND	3.1	ND	3.1	
40	12/12/2017	ND	ND	ND	ND	ND	
40	12/27/2017	ND	ND	ND	ND	ND	
40	1/10/2018	ND	ND	3.3	ND	3.3	
40	1/23/2018	ND	ND	ND	ND	ND	
40	2/7/2018	ND	ND	ND	ND	ND	
40	2/27/2018	ND	ND	ND	ND	ND	

40	3/6/2018	ND	ND	ND	ND	ND
40	3/23/2018	ND	ND	ND	ND	ND
40	4/3/2018	ND	ND	ND	ND	ND
40	4/18/2018	ND	ND	ND	ND	ND
40	5/1/2018	ND	ND	2.7	ND	2.7
40	5/15/2018	ND	ND	ND	ND	ND
40	5/30/2018	ND	ND	ND	ND	ND
40	6/26/2018	ND	ND	ND	ND	ND
40	7/11/2018	ND	ND	ND	ND	ND
40	8/9/2018	ND	ND	ND	ND	ND
40	8/22/2018	ND	ND	ND	ND	ND
40	9/5/2018	ND	ND	ND	ND	ND
40	9/19/2018	ND	ND	ND	ND	ND
40	10/3/2018	ND	ND	ND	ND	ND
40	10/17/2018	ND	ND	ND	ND	ND
40	10/31/2018	ND	ND	ND	ND	ND
40	11/14/2018	ND	ND	3.2	ND	3.2
40	11/28/2018	ND	ND	ND	ND	ND
40	12/19/2018	ND	ND	ND	ND	ND
40	12/27/2018	ND	ND	ND	ND	ND
40	1/9/2019	ND	ND	ND	ND	ND

GAC change
out
12/4/2018

Well 40 Treated Water - Currently Active

