

Well No.	Sample Collection Date	Perfluorooctanesulfonic acid PFOS C <sub>8</sub> HF <sub>17</sub> O <sub>3</sub> S	Perfluorooctanoic acid PFOA C <sub>8</sub> HF <sub>15</sub> O <sub>2</sub>	Combined PFOS PFOA	Perfluorohexanesulfonic acid PFHxS C <sub>6</sub> HF <sub>13</sub> O <sub>3</sub> S	Perfluorononanoic acid PFNA C <sub>9</sub> HF <sub>17</sub> O <sub>2</sub>	Perfluorobutanesulfonic acid PFBS C <sub>4</sub> HF <sub>9</sub> O <sub>3</sub> S	Perfluoroheptanoic acid PFHpA C <sub>7</sub> HF <sub>13</sub> O <sub>2</sub>	Perfluorohexanoic acid PFHxA <sup>7</sup> C <sub>6</sub> HF <sub>11</sub> O <sub>2</sub>	
	Date	PFOS (ppt)	PFOA (ppt)	Combined PFOS/PFOA (ppt)	PFHxS (ppt)	PFNA (ppt)	PFBS (ppt)	PFHpA (ppt)	PFHxA (ppt)	Comments
4	12/15/2015	8.4	9.1	17.5	5.2	ND	3.3	3.7	5.7	
4	5/10/2016	10.0	6.3	16.3	4.1	ND	ND	ND	3.6	
4	7/27/2016	17.0	5.9	22.9	7.2	ND	2.6	2.8	3.7	
4	8/10/2016	18.0	9.2	27.2	6.6	ND	3.8	3.7	5.4	
4	9/22/2016	13.0	10.0	23.0	4.6	ND	3.0	3.5	6.3	
4	10/12/2016	16.0	10.0	26.0	7.1	ND	4.0	4.0	6.0	
4	10/25/2016	15.0	8.8	23.8	6.5	ND	3.6	3.6	6.4	
4	11/9/2016	15.0	8.9	23.9	6.2	ND	3.6	3.4	5.3	
4	12/1/2016	14.0	7.5	21.5	6.3	ND	3.6	2.9	5.3	
4	12/14/2016	14.0	7.5	21.5	6.3	ND	3.6	2.9	5.3	
4	1/11/2017	8.8	6.9	15.7	7.0	ND	4.0	2.9	4.6	
4	2/1/2017	22.2	9.6	31.8						
4	3/8/2017	15.0	8.7	23.7	6.7	ND	3.8	3.3	5.4	
4	4/4/2017	14.7	9.6	24.3						
4	5/2/2017	17.0	10.0	27.0						
4	5/31/2017	19.0	5.8	24.8						
4	7/7/2017	18.0	7.8	25.8	12.0	ND	2.9	3.1		
4	7/21/2017	18.0	7.5	25.5	13.0	ND	3.2	3.0		
4	8/1/2017	18.0	7.2	25.2	9.9	ND	ND	2.6		
4	8/16/2017	15.0	6.9	21.9	9.0	ND	3.2	4.1		
4	9/7/2017	15.0	5.5	20.5	11.0	ND	3.0	ND		
4	9/19/2017	16.0	6.0	22.0	7.9	ND	ND	ND		
4	10/4/2017	18.0	5.9	23.9	13.0	ND	3.0	ND		
4	10/17/2017	18.0	6.1	24.1	11.0	ND	2.5	ND		
4	11/9/2017	18.0	5.6	23.6	7.6	ND	2.7	ND		
4	11/22/2017	14.0	5.4	19.4	7.2	ND	ND	ND		
4	12/5/2017	14.0	5.5	19.5	8.6	ND	2.7	2.5		
4	12/19/2017	18.0	6.9	24.9	11.0	ND	2.9	2.7		
4	1/5/2018	18.0	6.5	24.5	8.1	ND	2.8	2.7		
4	1/16/2018	17.0	6.4	23.4	8.1	ND	2.6	3.4		
4	2/6/2018	16.0	5.1	21.1	7.9	ND	2.4	ND		Values in red mean lab is not certified in PA for compound
4	6/5/2019	10.0	4.3	14.3	4.9	ND	ND	ND	2.7	Well 4 placed back in service on 8/30/2019
4	9/4/2019	8.6	5.9	14.5	3.2	ND	2.7	2.5	4.4	
4	10/30/2019	11.0	8.1	19.1	5.3	ND	3.9	3.0	4.8	
4	11/12/2019	13.0	11.0	24.0	6.2	ND	5.1	4.4	5.9	
4	11/25/2019	16.0	8.3	24.3	5.6	ND	5.0	3.9	7.4	
4	11/27/2019	14.0	9.5	23.5	5.8	ND	5.0	4.2	6.4	Eurofins 537
4	12/5/2019	12.0	6.8	18.8	4.9	ND	4.1	3.7	5.5	
4	12/10/2019	11.0	7.4	18.4	4.2	ND	3.7	3.5	4.3	
4	12/26/2019	14.0	11.0	25.0	5.9	ND	5.2	5.8	7.5	
4	1/8/2020	11.0	9.6	20.6	5.3	ND	5.0	4.8	6.7	
4	1/8/2020	14.0	9.0	23.0	5.6	ND	4.4	3.6	5.7	Eurofins 537.1
4	1/22/2020	16.0	12.0	28.0	7.2	ND	5.9	5.8	9.1	
4	2/4/2020	15.0	9.3	24.3	5.9	ND	6.0	4.2	7.6	
4	2/17/2020	14.0	6.9	20.9	7.8	ND	3.1	2.6	5.5	
4	3/4/2020	14.0	8.2	22.2	4.9	ND	4.9	3.5	6.7	
4	3/18/2020	11.0	9.1	20.1	5.0	ND	4.1	3.2	5.1	
4	3/31/2020	9.1	9.4	18.5	4.6	ND	4.4	2.6	5.6	

4	4/15/2020	17.0	10.0	27.0	4.6	ND	5.5	3.2	6.0	
4	4/28/2020	6.8	11.0	17.8	6.5	ND	5.8	4.1	8.8	
4	5/12/2020	12.0	7.7	19.7	5.1	ND	4.2	ND	5.0	Sampling reduced to monthly per PADEP
4	6/10/2020									No sample due to power failure
4	7/8/2020	19.0	12.0	31.0	8.3	ND	7.3	4.3	7.7	

