

Source	Sample Collection Date	PFOS Result (ppt)	PFOA Result (ppt)	Combined PFOS PFOA total concentration (ppt)	Combined PFOS PFOA Health Advisory issued 5/19/16 (ppt)	Notes
NWWA Interconnect	7/11/2014	ND	ND	ND		UCMR Higher detection levels
NWWA Interconnect	9/24/2014	ND	ND	ND		UCMR Higher detection levels
NWWA Interconnect	12/10/2014	ND	ND	ND		UCMR Higher detection levels
NWWA Interconnect	3/19/2015	ND	ND	ND		UCMR Higher detection levels
NWWA Interconnect	4/13/2016	ND	ND	ND	70.0	Sample results are water entering HWSA system at interconnection w NWWA
NWWA Interconnect	10/5/2016	ND	ND	ND	70.0	Sample results are finished water leaving Forest Park Water Treatment Plant
NWWA Interconnect	11/16/2016	ND	ND	ND	70.0	Sample results are finished water leaving Forest Park Water Treatment Plant
NWWA Interconnect	12/27/2016	ND	2.2	2.2	70.0	Sample results are finished water leaving Forest Park Water Treatment Plant

NWWA Interconnect	5/31/2017	ND	2.9	2.9	70.0	Sample results are finished water leaving Forest Park Water Treatment Plant
NWWA Interconnect	9/29/2017	ND	2.3	2.3	70.0	Sample results are finished water leaving Forest Park Water Treatment Plant
NWWA Interconnect	1/31/2018	ND	3.3	3.3	70.0	Sample results are finished water leaving Forest Park Water Treatment Plant
NWWA Interconnect	2/28/2018	2.0	3.4	5.4	70.0	Sample results are finished water leaving Forest Park Water Treatment Plant
NWWA Interconnect	March-18	ND	3.2	3.2	70.0	Sample results are finished water leaving Forest Park Water Treatment Plant
NWWA Interconnect	April-18	ND	3.0	3.0	70.0	Sample results are finished water leaving Forest Park Water Treatment Plant
NWWA Interconnect	May-18	2.3	4.1	6.4	70.0	Sample results are finished water leaving Forest Park Water Treatment Plant
NWWA Interconnect	June-18	2.3	4.2	6.5	70.0	Sample results are finished water leaving Forest Park Water Treatment Plant
NWWA Interconnect	July-18	2.2	4.0	6.2	70.0	Sample results are finished water leaving Forest Park Water Treatment Plant
NWWA Interconnect	August-18	2.3	4.5	6.8	70.0	Sample results are finished water leaving Forest Park Water Treatment Plant

NWWA Interconnect	September-18	ND	4.3	4.3	70.0	Sample results are finished water leaving Forest Park Water Treatment Plant
NWWA Interconnect	October-18	2.3	4.4	6.7	70.0	Sample results are finished water leaving Forest Park Water Treatment Plant
NWWA Interconnect	November-18	2.3	4.5	6.8	70.0	Sample results are finished water leaving Forest Park Water Treatment Plant
NWWA Interconnect	December-18	2.2	4.5	6.7	70.0	Sample results are finished water leaving Forest Park Water Treatment Plant
NWWA Interconnect	January-19	2.2	4.2	6.4	70.0	Sample results are finished water leaving Forest Park Water Treatment Plant
NWWA Interconnect	February-19	2.4	3.7	6.1	70.0	Sample results are finished water leaving Forest Park Water Treatment Plant
NWWA Interconnect	March-19	2.5	3.6	6.1	70.0	Sample results are finished water leaving Forest Park Water Treatment Plant

# Noth Wales Water Authority Water - Active

