

| Sample Collection Date | PFOS Result (ppt) | PFOA Result (ppt) | Combined PFOS/ PFOA total concentration (ppt) | PFHxS Result (ppt) | PFNA Result (ppt) | PFBS Result (ppt) | PFHpA Result (ppt) | Notes   |
|------------------------|-------------------|-------------------|---|--------------------|-------------------|-------------------|--------------------|---|
| 7/11/2014              | ND                | ND                | ND  |                    |                   |                   |                    | UCMR Higher detection levels  |
| 9/24/2014              | ND                | ND                | ND  |                    |                   |                   |                    | UCMR Higher detection levels  |
| 12/10/2014             | ND                | ND                | ND  |                    |                   |                   |                    | UCMR Higher detection levels  |
| 3/19/2015              | ND                | ND                | ND  |                    |                   |                   |                    | UCMR Higher detection levels  |
| 4/13/2016              | ND                | ND                | ND  |                    |                   |                   |                    | Sample results are water entering HWSA system at interconnection w NWWA     |
| 10/5/2016              | ND                | ND                | ND  | ND                 | ND                | ND                | ND                 | Sample results are finished water leaving Forest Park Water Treatment Plant |
| 11/16/2016             | ND                | ND                | ND  | ND                 | ND                | ND                | ND                 | Sample results are finished water leaving Forest Park Water Treatment Plant |

|            |     |     |     |    |    |    |    |   |
|------------|-----|-----|-----|----|----|----|----|---|
| 12/27/2016 | ND  | 2.2 | 2.2 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| 5/31/2017  | ND  | 2.9 | 2.9 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| 9/29/2017  | ND  | 2.3 | 2.3 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| 1/31/2018  | ND  | 3.3 | 3.3 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| 2/28/2018  | 2.0 | 3.4 | 5.4 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| March-18   | ND  | 3.2 | 3.2 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| April-18   | ND  | 3.0 | 3.0 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| May-18     | 2.3 | 4.1 | 6.4 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| June-18    | 2.3 | 4.2 | 6.5 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |

|              |     |     |     |    |    |     |     |   |
|--------------|-----|-----|-----|----|----|-----|-----|---|
| July-18      | 2.2 | 4.0 | 6.2 | ND | ND | ND  | ND  | Sample results are finished water leaving Forest Park Water Treatment Plant |
| August-18    | 2.3 | 4.5 | 6.8 | ND | ND | 2.0 | 2.1 | Sample results are finished water leaving Forest Park Water Treatment Plant |
| September-18 | ND  | 4.3 | 4.3 | ND | ND | 2.2 | 2.0 | Sample results are finished water leaving Forest Park Water Treatment Plant |
| October-18   | 2.3 | 4.4 | 6.7 | ND | ND | ND  | ND  | Sample results are finished water leaving Forest Park Water Treatment Plant |
| November-18  | 2.3 | 4.5 | 6.8 | ND | ND | ND  | 2.1 | Sample results are finished water leaving Forest Park Water Treatment Plant |
| December-18  | 2.2 | 4.5 | 6.7 | ND | ND | ND  | 2.0 | Sample results are finished water leaving Forest Park Water Treatment Plant |
| January-19   | 2.2 | 4.2 | 6.4 | ND | ND | ND  | ND  | Sample results are finished water leaving Forest Park Water Treatment Plant |
| February-19  | 2.4 | 3.7 | 6.1 | ND | ND | ND  | ND  | Sample results are finished water leaving Forest Park Water Treatment Plant |
| March-19     | 2.5 | 3.6 | 6.1 | ND | ND | ND  | ND  | Sample results are finished water leaving Forest Park Water Treatment Plant |

|              |     |     |     |    |    |    |    |   |
|--------------|-----|-----|-----|----|----|----|----|---|
| June-19      | 2.4 | 4.2 | 6.6 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| July-19      | ND  | 2.6 | 2.6 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| September-19 | ND  | 2.5 | 2.5 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| October-19   | ND  | 2.1 | 2.1 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| November-19  | 2.4 | 3.0 | 5.4 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| December-19  | ND  | 2.4 | 2.4 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| January-20   | ND  | 2.1 | 2.1 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| February-20  | ND  | ND  | ND  | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| March-20     | ND  | 2.0 | 2.0 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |

|              |    |     |     |    |    |    |    |   |
|--------------|----|-----|-----|----|----|----|----|---|
| April-20     | ND | 2.4 | 2.4 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| May-20       | ND | ND  | ND  | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| June-20      | ND | ND  | ND  | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| July-20      | ND | ND  | ND  | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| August-20    | ND | ND  | ND  | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| September-20 | ND | ND  | ND  | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| October-20   | ND | ND  | ND  | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| November-20  | ND | 2.3 | 2.3 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| December-20  | ND | 2.0 | 2.0 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |

|              |    |     |     |    |    |    |    |   |
|--------------|----|-----|-----|----|----|----|----|---|
| January-21   | ND | 2.3 | 2.3 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| February-21  | ND | 2.5 | 2.5 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| March-21     | ND | 2.2 | 2.2 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| April-21     | ND | 2.2 | 2.2 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| May-21       | ND | ND  | ND  | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| June-21      | ND | 2.1 | 2.1 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| July-21      | ND | 2.5 | 2.5 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| August-21    | ND | 2.5 | 2.5 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| September-21 | ND | 2.5 | 2.5 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |

|             |    |     |     |    |    |    |    |   |
|-------------|----|-----|-----|----|----|----|----|---|
| October-21  | ND | 2.2 | 2.2 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| November-21 | ND | 2.3 | 2.3 | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |
| December-21 | ND | ND  | ND  | ND | ND | ND | ND | Sample results are finished water leaving Forest Park Water Treatment Plant |

### Noth Wales Water Authority Water - Active

