

Sample Collection Date	PFOS Result (ppt)	PFOA Result (ppt)	Combined PFOS/ PFOA total concentration (ppt)	PFHxS Result (ppt)	PFNA Result (ppt)	PFBS Result (ppt)	PFHpA Result (ppt)	Notes
7/11/2014	ND	ND	ND					UCMR Higher detection levels
9/24/2014	ND	ND	ND					UCMR Higher detection levels
12/10/2014	ND	ND	ND					UCMR Higher detection levels
3/19/2015	ND	ND	ND					UCMR Higher detection levels
4/13/2016	ND	ND	ND					Sample results are water entering HWSA system at interconnection w NWWA
10/5/2016	ND	ND	ND	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
11/16/2016	ND	ND	ND	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant

12/27/2016	ND	2.2	2.2	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
5/31/2017	ND	2.9	2.9	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
9/29/2017	ND	2.3	2.3	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
1/31/2018	ND	3.3	3.3	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
2/28/2018	2.0	3.4	5.4	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
March-18	ND	3.2	3.2	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
April-18	ND	3.0	3.0	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
May-18	2.3	4.1	6.4	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
June-18	2.3	4.2	6.5	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant

July-18	2.2	4.0	6.2	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
August-18	2.3	4.5	6.8	ND	ND	2.0	2.1	Sample results are finished water leaving Forest Park Water Treatment Plant
September-18	ND	4.3	4.3	ND	ND	2.2	2.0	Sample results are finished water leaving Forest Park Water Treatment Plant
October-18	2.3	4.4	6.7	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
November-18	2.3	4.5	6.8	ND	ND	ND	2.1	Sample results are finished water leaving Forest Park Water Treatment Plant
December-18	2.2	4.5	6.7	ND	ND	ND	2.0	Sample results are finished water leaving Forest Park Water Treatment Plant
January-19	2.2	4.2	6.4	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
February-19	2.4	3.7	6.1	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
March-19	2.5	3.6	6.1	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant

June-19	2.4	4.2	6.6	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
July-19	ND	2.6	2.6	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
September-19	ND	2.5	2.5	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
October-19	ND	2.1	2.1	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
November-19	2.4	3.0	5.4	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
December-19	ND	2.4	2.4	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
January-20	ND	2.1	2.1	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
February-20	ND	ND	ND	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
March-20	ND	2.0	2.0	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant

April-20	ND	2.4	2.4	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
May-20	ND	ND	ND	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant
June-20	ND	ND	ND	ND	ND	ND	ND	Sample results are finished water leaving Forest Park Water Treatment Plant

