



NOTES:

1. CONCRETE THRUST BLOCK TO BE SIZED FOR HORIZONTAL THRUST FROM UPSTREAM PIPE DIAMETER.

HORSHAM WATER & SEWER AUTHORITY

DETAIL W3

SURFACE BLOW-OFF

DATE:

MARCH 23, 2015

SCALE:

NOT TO SCALE