



**NOTES:**

1. FOR TAPS > 1" CONNECTION, PROVIDE TAPPING SADDLE IN ACCORDANCE WITH AUTHORITY SPECIFICATIONS.
2. DO NOT PLACE CURB BOX IN PAVED AREAS.
3. WHERE SIDEWALK PARALLELS ROADWAY, THE CURB BOX SHALL BE PLACED BETWEEN THE CURB AND SIDEWALK. ALL OTHER LOCATIONS, CURB BOX TO BE PLACED WHERE DIRECTED BY AUTHORITY.
4. CUSTOMER IS RESPONSIBLE FOR MAINTENANCE OF ALL SERVICE PIPING AND PLUMBING BEYOND THE CURB STOP, WITH EXCEPTION OF WATER METER.
5. PROVIDE COMPRESSION FITTINGS ON CURB AND CORPORATION STOP.
6. NOTIFY AUTHORITY WHEN WATER SERVICE IS READY FOR INSPECTION AND TESTING. DO NOT BACKFILL TRENCH UNTIL INSPECTION IS COMPLETE.
7. PIPE SHALL BE CONTINUOUS FROM CORPORATION STOP TO CURB STOP AND FROM CURB STOP TO BUILDING.

**HORSHAM WATER & SEWER AUTHORITY**

**DETAIL W4**

**STANDARD WATER SERVICE CONNECTION**

DATE:

JUNE 4, 2015

SCALE:

NOT TO SCALE