



NOTES:

1. CATALOG NUMBERS SHOWN ARE AS MANUFACTURED BY THE FORD METER BOX COMPANY, INC. 'X' IN CATALOG NUMBERS SHOULD BE REPLACED PER THE FORD CATALOG TO INDICATE THE TYPE OF INLET AND OR OUTLET REQUIRED.
2. PROVIDE TWO (2) COPPER OR BRASS REDUCERS AT INLET AND OUTLET FOR 1-1/2" SERVICE.
3. METER PIT SHALL BE 36" I.D. PVC SONO-LOC AS MANUFACTURED BY SONOCO PRODUCTS, OR APPROVED EQUAL.
4. METER PIT COVER SHALL BE MONITOR COVER WITH INNER LID, MC-36-MB, AS MANUFACTURED BY THE FORD METER BOX COMPANY, INC. OR APPROVED EQUAL.
5. DOMESTIC SERVICE REQUIRES BACKFLOW DEVICE. BACKFLOW DEVICE TO BE LOCATED ON SERVICE LINE AT ENTRY POINT INTO BLDG. BEFORE ANY CONNECTIONS.
6. MARK INLET, OUTLET, & DIRECTION OF FLOW ON UNIT.
7. ALL BRASS OF 85-5-5 RED BRASS AWWA C800-89 ASTM B62-93.

ITEM	DESCRIPTION	QTY.	CAT. NO.
1	ANGLE BALL VALVE	1	BFAX3-777W-MSB
2	METER ADAPTERS/PAIR	1	A67
3	ANGLE DUAL CHK VALVE	1	HFFA3X-777-MSB
4	BALL VALVE	1	BXX-777-HB-67
5	SOLDER BUSHING	2	CS8-77
6	TEE	2	CSTEE-7B-T
7	BALL VALVE	1	BXX-455W
8	BOLT & NUT / PR	2	PSB
9	MONITOR COVER W/ INNER LID*	1	MC-36-MB

* ORDERED SEPARATELY

HORSHAM WATER & SEWER AUTHORITY

DETAIL W6

**1 1/2" & 2" WATER METER
PIT FOR LOW PRESSURE
SERVICE**

DATE:

MARCH 23, 2015

SCALE:

NOT TO SCALE